

FIRE EXTINGUISHERS

HALOCARBON SPECIFICATIONS

- *The shell is manufactured by plastering method and painted with electrostatic powder paint.
- *30 BAR Hydrostatic shell test are applied to devices.
- *The trigger mechanism has CE certification.
- *Our extinguishers have pressure gauge with filter
- *UL listed, FM approved HFC 227ea gas is used in extinguishers.
- *The extinguishers have special hanger sets.
- *Halacarbon does not damage the electronic devices and environment.
- *Halacarbon is non-toxic, colorless and contains high performance liquid gases.
- *We have TSE 862 EN 3, CE and ISO 9001-2008 certificates.



FIRE EXTINGUISHERS SPECIFICATIONS

- *The shell is manufactured by tensile steel method and seamless, painted with electrostatic powder paint.
- *250 BAR hydrostatic shell test are applied to devices.
- *The trigger mechanism is CE certificated
- *We have TSE 862 EN 3, CE and ISO 9001-2008 certificates.

FOAM SPRAY SPECIFICATIONS

- *The shell is manufactured by plastering method and painted with electrostatic powder paint.
- *30 BAR Hydrostatic shell test are applied to devices.
- *The trigger mechanism has CE certification.
- *Our extinguishers have pressure gauge with filter.
- *%6 synthetic foam is used in extinguishers.
- *The extinguishers have special hanger sets.
- *We have TSE 862 EN 3-7, CE and ISO 9001-2008 certification.



TSE EN 1866-1:2007
FYG
A YANGIN GÜVENLİK SİSTEMLERİ SAN. TİC. A.Ş.

YANGIN SÖNDÜRÜCÜ
25 KG ABC TOZ C

1-NOZULU VE HORTUMU YERİNDEN ÇIKARINIZ	1
2-EMNİYET PİMİNİ ÇEKİNİZ	2
3-VANAYI SOLA DOĞRU SONUNA KADAR ÇEVİRİNİZ	3
4-NOZULU ALEVE YÖNELTİP, TETİĞE BASINIZ	4

DİKKAT
1 M UZAKLIKTAN 1000 V'a KADAR, ÜZERİNDEN ELEKTRİK AKIMI GEÇEN TEÇHİZAT ÜZERİNDE KULLANIMA UYGUNDUR

İMALATÇI FİRMA
A YANGIN GÜVENLİK SİSTEMLERİ SAN. TİC. A.Ş.
Yeniçeri, Sultan Selim Caddesi, No:100, Kat:1, Beşiktaş/İstanbul
Tel: 0212 854 62 84 • www.yangin.com • e-mail: ays@yangin.com